

## State of Louisiana

Department of Health and Hospitals
Office of the Secretary

December 30, 2009

Mr. Kenneth Folse District Manager, Louisiana Viega, LLC. 301 North Main, Floor 9 Wichita, KS 67202

Re:

Use of Viega Fostapex® piping sizes ½", ¾", and 1" for Water Service Pipe and Water Distribution Pipe

for Plumbing Installations

Dear Mr. Folse:

Receipt is acknowledged of your request letter dated November 3, 2009 and submittal package delivered via email to Mr. Jake Causey, P.E., relative to requesting approval of the above referenced plumbing product for use in the State of Louisiana.

Your inquiry essentially requested that Viega Fostapex® piping sizes ½", ¾", and 1" be approved under Section 102.7 "Alternate Materials and Methods of Construction" of the Louisiana State Plumbing Code, 2000 Edition (LSPC). This Section allows the use of any material or method of construction not specifically prescribed under the LSPC provided that any such alternate has been approved by the Plumbing Official. Section 202 of the LSPC defines the Plumbing Official as: i.) the State Health Officer (= co-State Plumbing Official), and ii.) any local Plumbing Department (= co-Local Plumbing Official) established and authorized by a political subdivision of the state. After our discussions and review of the literature, etc., provided, please be advised that this office offers no objection to the use of Viega Fostapex® piping sizes ½", ¾", and 1" in Louisiana for potable water service and potable water distribution purposes within plumbing installations as long as the following stipulations are met:

- 1.) Pursuant to Section 303.5 of the LSPC, in the absence of installation procedures contained in a standard under which the materials are accepted and approved, it is required that the manufacturer's published procedures or recommendations shall be followed. Installation procedures and recommendations from the manufacturer are contained in the Viega PureFlow Water System Installation Manaul, March 2007. Such installation procedures and recommendations shall be followed.
- 2.) All joints shall be made using the standard Viega Pureflow Pex Press Fitting system.

Please be advised that this action does not abrogate your responsibility to obtain similar approval from those local jurisdictions having its own local Plumbing Department (= co-Local Plumbing

Official) since the local jurisdiction's requirements may be stricter than the requirements of the LSPC. Should you have any questions, please do not hesitate to contact my staff at (225) 342-7273.

Sincerely,

Jimmy Gyidry, M.D.

State Health Officer

## JKC/jkc

cc: Karen Irion, Chief Engineer, OPH

Sidney Becnel, Center for Environmental Health Services, OPH

Jake Causey, Engineer, Engineering Services Section, OPH

District/Regional Engineers, Engineering Services Section, OPH

Rene' Chedraui, Director, Engineering & Consulting Services, LDHH

John Barker, Executive Director, State Plumbing Board of Louisiana

Butch Browning, State Fire Marshal, Office of the State Fire Marshal, Department of Public Safety and Corrections

Denise Jobe, Building Codes Administrator, Louisiana State Uniform Construction

Code Council, c/o Office of Management and Finance, Department of Public Safety and

Michael McDuff, Executive Director, State Licensing Board for Contractors

Local Plumbing Inspectors in LA (from S. Becnel's Excel list)